



WOOD NAILER ATTACHED TO SUBSTRATE - OVERALL THICKNESS TO MATCH INSULATION

4" MIN.

WALL ASSEMBLY

APPROVED MASTIC OR SEALANT AT JUNCTION OF MEMBRANE AND EDGE METAL

SBS SMOOTH MODIFIED BITUMEN BACKER SHEET REQUIRED IN 15 AND 20 YEAR SYSTEMS ONLY

SBS TG MODIFIED BITUMEN FLASHING, HEAT WELDED

APPROX. 4"

APPROX. 4"

PRIMED METAL EDGE FLASHING, MIN. 4" FLANGE, SET IN USP #640 STANDARD ROOF CEMENT OR DURAFLEX 954 PREMIUM SBS FLASHING CEMENT

SBS MODIFIED BITUMEN MEMBRANE

FASTENERS 3" O.C. (TYPICAL) STAGGERED

BASE/PLY SHEET(S)

RIGID INSULATION

**NOTES:**

1. BASE/PLY SHEET(S) AND MEMBRANE TURNED OVER EDGE AND EXTENDED BELOW BLOCKING OR A MINIMUM OF 1 1/2" (38 MM), WHICHEVER IS GREATER.
2. 15 & 20 YEAR DETAIL: SBS SMOOTH MODIFIED BITUMEN BACKER SHEET AND SBS GRANULE SURFACED MODIFIED BITUMEN MEMBRANE ARE APPLIED OVER METAL FLANGE.
3. APPROVED MASTIC OR SEALANTS ARE DURAFLEX 954 PREMIUM SBS FLASHING CEMENT, PLYLINK CONSTRUCTION ADHESIVE/SEALANT, OR LIQUA-PLY FLASHING.
4. DURAFLEX ALUM MAY BE USED FOR FLASHING MATERIAL IN LIEU OF HEAT WELDED SBS FLASHING MEMBRANE.

This detail is furnished "as is" and "as available" and for information only and as a guide for use in conjunction with U.S. Ply products with applicable construction conditions. All dimensions shown are sheet specific; do not scale off of drawing. All details must be checked by the user's designer, architect or engineer to ensure that design is adequate for intended use. Any alterations made to this detail become the design of the user and shall neither be assumed nor construed as U.S. Ply's design. U.S. Ply will not be liable for damages of any kind arising from the use of this website, and/or details, including direct, indirect, incidental, consequential and punitive damages.



**U.S. PLY, INC.**

*Pioneered with performance in mind... Engineered to stand the test of time.*

TITLE:  
**SBS PERIMETER FLASHING DETAIL**

DATE: <b>05-14-2004</b>	SCALE: <b>N.T.S.</b>
REVISIONS: <b>01-31-2011</b>	<b>DFTG-1</b>