



4" MIN.

WOOD NAILER ATTACHED TO SUBSTRATE - OVERALL THICKNESS TO MATCH INSULATION

WALL ASSEMBLY
RIGID INSULATION

APPROVED MASTIC OR SEALANT AT JUNCTION OF MEMBRANE AND EDGE METAL

APP SMOOTH MODIFIED BITUMEN BACKER SHEET REQUIRED IN 15 AND 20 YEAR SYSTEMS ONLY

APP MODIFIED BITUMEN MEMBRANE

4"

4"

PRIMED METAL EDGE FLASHING, MIN. 4" FLANGE, SET IN SOFTENED MEMBRANE OR SAFEWELD PREMIUM APP FLASHING CEMENT

APP PRE-FLASHING

FASTENERS 3" O.C. STAGGERED (TYPICAL)

BASE/PLY SHEET(S)

NOTES:

1. BASE/PLY SHEET(S) AND APP PRE-FLASHING TURNED OVER EDGE AND EXTENDED BELOW BLOCKING OR A MINIMUM OF 1 1/2" (38 MM), WHICHEVER IS GREATER.
2. 15 & 20 YEAR DETAIL: APP SMOOTH MODIFIED BITUMEN BACKER SHEET AND APP GRANULE SURFACED MODIFIED BITUMEN MEMBRANE ARE APPLIED OVER METAL FLANGE.
3. APPROVED MASTIC OR SEALANTS ARE SAFEWELD PREMIUM APP FLASHING CEMENT, PLYLINK CONSTRUCTION ADHESIVE/SEALANT, OR LIQUA-PLY FLASHING.

This detail is furnished "as is" and "as available" and for information only and as a guide for use in conjunction with U.S. Ply products with applicable construction conditions. All dimensions shown are sheet specific; do not scale off of drawing. All details must be checked by the user's designer, architect or engineer to ensure that design is adequate for intended use. Any alterations made to this detail become the design of the user and shall neither be assumed nor construed as U.S. Ply's design. U.S. Ply will not be liable for damages of any kind arising from the use of this website, and/or details, including direct, indirect, incidental, consequential and punitive damages.



U.S. PLY, INC.

Pioneered with performance in mind... Engineered to stand the test of time.

TITLE:

APP PERIMETER FLASHING DETAIL (GRANULATED)

DATE:
05-14-2004

REVISIONS:
01-31-2011

SCALE:
N.T.S.

DW-2