



HEAVY METAL CAP FASCIA. 10'-0" MAX.

APP MODIFIED BITUMEN FLASHING, SET IN SAFEWELD PREMIUM APP FLASHING CEMENT OR HEAT WELDED

FASTENERS 8" O.C. (TYPICAL)

WOOD CANT

WOOD NAILER ATTACHED TO SUBSTRATE - OVERALL THICKNESS TO MATCH INSULATION

WALL ASSEMBLY

6" MIN

SAFEWELD™ APP SMOOTH MODIFIED BITUMEN BACKER SHEET TURNED DOWN OVER EDGE AND EXTENDED BEYOND BLOCKING / WOOD NAILER

SAFEWELD™ APP MODIFIED BITUMEN MEMBRANE

BASE/PLY SHEET(S)

NOTES:

1. FASTENERS SHALL BE PLACED IN EACH SECTION OF CAP FASCIA IN ACCORDANCE WITH SMACNA REQUIREMENTS AND WIND LOAD REQUIREMENTS.
2. COVER PLATE SHALL BE EMBEDDED IN PLYLINK HP SEALANT OR OTHER APPROVED SEALANT. TWO FASTENERS SHALL BE PLACED AT THE CENTER OF EACH SECTION OF CAP FASCIA AND COVER PLATE. SEAL FASTENERS WITH PLYLINK HP SEALANT OR OTHER APPROVED SEALANT.
3. SAFEWELD™ APP MEMBRANES MAY BE HEAT WELDED IN LIEU OF APPLICATION IN SAFEWELD™ PREMIUM APP MODIFIED ADHESIVE. REFER TO DURAWELD SPECIFICATIONS FOR HEAT WELDING PRECAUTIONS AND REQUIREMENTS.

This detail is furnished "as is" and "as available" and for information only and as a guide for use in conjunction with U.S. Ply products with applicable construction conditions. All dimensions shown are sheet specific; do not scale off of drawing. All details must be checked by the user's designer, architect or engineer to ensure that design is adequate for intended use. Any alterations made to this detail become the design of the user and shall neither be assumed nor construed as U.S. Ply's design. U.S. Ply will not be liable for damages of any kind arising from the use of this website, and/or details, including direct, indirect, incidental, consequential and punitive damages.



U.S. PLY, INC.

Pioneered with performance in mind... Engineered to stand the test of time.

TITLE:
APP PERIMETER CURB FLASHING DETAIL

DATE:
05-14-2004

SCALE:
N.T.S.

REVISIONS:
01-31-2011

| |
|--|
| |
| |
| |
| |

SW-3